

**INDIRA GANDHI INSTITUTE OF MEDICAL SCIENCES,**

SHEIKHUPURA, PATNA - 800 014 (Bihar, India)

Tel.: 0612 - 2297631, 2297099; Fax: 0612 - 2297225; Website: [www.igims.org](http://www.igims.org);E-Mail: [director@igims.org](mailto:director@igims.org)

Ref. No.: 826/EC /2024

Dated: 09/02/2024

**Corrigendum cum Outcome of Pre-Bid**

Amendment Notice to the E-TENDER NOTICE NO:-IGIMS/EC/EW/09/2023-24 for the Work namely "Supply, Installation, Testing & commissioning of 2000 KVA, 33/0.433 KV Transformer along with DG Set, Electrical Panels and associated Electrical Works in 33 KV Substation at IGIMS, Patna-14". During Pre-Bid, Meeting doubts raised by prospective bidders were acknowledged and made clear during discussion. After careful consideration of the points raised by the prospective bidders and to ensure maximum participation to the bidder following amendments in price bid in scope of work mentioned here under are notified.

Sl. No.	NIT / BOQ Page No.	Clause No./Line Item No.	Bidder Query	Clarification of Query as follows:
1	2	26	<ul style="list-style-type: none"><li>SITC of 750 KVA silent DG Set comprising of Cummins make engine model KTA-38-G12 developing 1069 BHP Coupled to 750 KVA, 415 V STAMFORD make alternator mounted on a common base frame, complete with: (a) Fuel tank 990 Ltrs (Outside Enclosure) ,(b) AVM Pads, (c) Silencer, (d) Radiator, (e) Acoustic enclosure.</li></ul>	<ul style="list-style-type: none"><li>The make and model mentioned in the NIT may be deleted.</li><li>Prospective bidders may quote D.G. Set of reputed manufacturer having larger installation base and service / maintenance facility in State of Bihar.</li><li>The D. G. Set to be quoted must confirm the technical specifications mentioned in the NIT and CPCB norms for Noise and Emission level amended up to date and General Specifications for electrical works of DG sets .</li><li><b>Add On:</b> The Exhaust Pipe and its support structure are being added in the revised BOQ. It will be the responsibility of the successful bidder to inspect the installation site and surrounding buildings before quoting the rate for the installation of the Exhaust Pipe and its support structure. The design and drawing of the proposed Exhaust structure must comply the latest norms framed by Government of India and the same should be vetted by NIT / IIT.</li><li>It will be the responsibility of the successful bidder to get the clearance certificate of the D. G. Sets after successful installation by the technical experts of the Bihar State Pollution Control Board from pollution point of view</li></ul>
2	2	26	<ul style="list-style-type: none"><li>Make</li></ul>	
3	2	26	DG Set BSVI	

4	60	Defect Liability Period	In GCC and SCC, Defect Liability Period is 60 Months	<ul style="list-style-type: none"> <li>Comprehensive Maintenance of this work will be 36 months. Bidders are advised to quote the rate accordingly in the Revised Price Bid.</li> <li>During defect liability period, successful bidder will maintain the complete system with all spares and consumables including glassware and batteries.</li> <li>Complete system shall comprise of all the items mentioned in the BOQ.</li> <li>During defect liability period, successful bidder shall provide at least four maintenance visits per year at regular interval for usual maintenance and supervision. If successful bidder fails to provide these Preventive maintenance visits at regular interval, penalty will be pro-rata basis from the security deposits. Apart from above, successful bidder shall attend any number of breakdown calls of the complete system.</li> <li>Successful bidder should submit authorization certificate issued by OEM in their favour for the quoted items / equipments against the E -TENDER NOTICE NO: IGIMS / EC / EW / 09 / 2023 – 24 with declaration that they (OEM) will provide services during the defect liability period on the same terms &amp; conditions in case of failure of bidder. Any bid without proper authorization certificate by OEM against the said tender notice will not be accepted and summarily rejected.</li> </ul>
---	----	-------------------------	--	---

Note: The time period tender notification is revised as below:

	Presently	Should Be Read As
<b>Date for obtaining BOQ</b> (Only on <a href="http://www.eproc2.bihar.gov.in">www.eproc2.bihar.gov.in</a> )	/ / 2024	/ / 2024
<b>Last Date &amp; Time for uploading of complete tender Document</b> (Only on <a href="http://www.eproc2.bihar.gov.in">www.eproc2.bihar.gov.in</a> )	09/ 02/ 2024	22/02/ 2024
<b>Last Date &amp; Time for submission of complete tender Document Hard copy</b> at Director's Office IGIMS through Regd. /speed post/courier.	12/ 02 / 2024 up to 3:00 PM	23/02/ 2024 up to 3:00 PM

<b>Date &amp; Place of Opening of Tender</b> (Technical bid Only on <a href="http://www.eproc2.bihar.gov.in">www.eproc2.bihar.gov.in</a> )	Conference Room IGIMS, Patna 13/ 02/ 2024 at 3:00 PM	Conference Room IGIMS, Patna 26/ 02/ 2024 at 3:00 PM
1. Approved SBD uploaded shall be the Part of the NIT.		
2. Bidders are advised to quote the rate of item no -26 as changes done in the Revised Price Bid.		
3. Design and Drawing of Transformer, DG sets, Chimney for Exhaust piping of DG sets are to be submitted with the Technical Bids. Successful Bidder will be responsible for vetting of Design and Drawing of Transformer, DG sets and Chimney for Exhaust piping of DG sets from NIT / IIT before execution. The statutory fees for the same shall be deposited by the successful bidder. In addition to this, the fees to Electrical Inspectorate (Energy Department) etc. shall also be deposited by the successful bidder before energizing the transformer and DG sets. Contractors are advised to quote the rate accordingly.		
4. All other technical specifications, terms & conditions of the original tender document shall remain unchanged. This amendment shall be part of the tender document and become effective immediately in suppression to the earlier corresponding version.		

  
 Director  
 IGIMS, Patna | 21/2/24