

BIDDING DOCUMENT



For

Re-installation, Renovation and Extension of Medical Gas Pipeline System at Kidney Transplant Unit and Private Ward (Deluxe Room) of I.G.I.M.S. – Patna.

INDIRA GANDHI INSTITUTE OF MEDICAL SCIENCES,
SHEIKHPURA, PATNA – 800 014 (BIHAR)

CONTENTS

		Page No.
1. Schedule - 1	Instruction to Bidder	03 to 17
2. Schedule - 2	Schedule of Requirement	18
3. Schedule - 3	Technical Specifications	22

BIO-MEDICAL ENGINEERING

1. Instruction to Bidders

- 1.1 Bids are invited, for and on behalf of Director, Indira Gandhi Institute of Medical Sciences – Patna from established, reputed and experienced manufacturers or their authorized representatives for **Re-installation, Renovation and Extension of Medical Gas Pipeline System at Kidney Transplant Unit and Private Ward (Deluxe Room) of I.G.I.M.S. – Patna** as per the enclosed Technical Specifications (Annexure-I).
- 1.2 Bidders are invited to study the tender document and terms & conditions carefully. Submission of tender shall be deemed to have been done after careful study and examination of the tender document with full understanding of its implications.
- 1.3 The scope of work shall include Supply, Installation, Commissioning, & Satisfactory Demonstration. This will also include testing, packing, transportation, scheduling of transportation, transit insurance, delivery at sites, unloading, storage, job site storage, insurance, installation any other services associated with the delivery of the equipment and materials providing warranty of services and operation and maintenance of other related equipment / items required for complete installation. The successful bidder will assume full responsibility of the complete system until final acceptance.
- 1.4 It will be imperative on each bidder to fully acquaint himself with all the local conditions and factors which would have any effect on the performance of the System. No request for the change of price, or time, schedule of delivery of stores shall be entertained after the purchaser on account of any local condition or factor accepts the offer.
- 1.5 The bidders are required to have a survey including a site visit before furnishing the quotations and make further enquiries (if any) from **Senior Bio-Medical Engineer, I.G.I.M.S. - Patna**. Any expenses, in connection with the visit and surveys, shall be borne by the bidders themselves.

2. Schedule of Tender

- 2.1 The non-transferable Tender Document will be sold on payment of tender fee of Rs.2000/- (Rupees Two Thousand only - non-refundable) through demand draft payable at Patna drawn in favour of the Director, IGIMS, Patna.
- 2.2 The non-transferable tender document can be downloaded from the institute website www.igims.org. The cost of the tender document as stated in para 2.1 above is to be enclosed in a separate envelope with note “**Cost of Tender Document**” at the cover of the envelope.
- 2.3 The sealed bids will be **accepted up to 14 / 10 / 2015 up to 4:00 P.M.** by regd. / speed post / courier services in the office of the Director, IGIMS – Patna
- 2.4 The Commercial bids of the short listed bidders will be opened at the office of the Director, IGIMS – Patna as the case may be in the presence of their authorized representatives, if any. (The date of opening of commercial bids will be communicated to the technically successful bidders).
- 25 All the correspondences shall be addressed to the Office of the Director, I.G.I.M.S., Sheikhpura, Patna – 800 014 (Bihar, India)

3. On site functional assessment of the similar installation and equipment of the short listed Bidders will be undertaken, if necessary, by the Committee duly constituted by the IGIMS.

4. Purchaser's Right to Vary Quantities at the time of Award

The Purchaser reserves the right to vary the quantities and/or services and/ or split the order among the selected Bidders.

5. Purchaser's Right to accept any Bid and to reject any or all bids

The Purchaser reserves the right to accept any bid, and to annul the tender process and reject all bids at any time, without assigning any reason. Prior to award of Contract, without thereby incurring any liability to the affected Bidder or Bidders or any obligation to inform the affected Bidder or Bidders of the grounds for the Purchaser's action.

6. Bidder Qualification

The "Bidder" as used in the tender documents shall mean one who has signed the Bid Form. The Bidder may be either the manufacturer of the equipment/ material for which prices are quoted on the Price Schedule or his duly authorized representative, in which case he shall submit a certificate of authority. All certificates and documents received hereby, shall, as far as possible, be furnished by the manufacturer/ representative of the firm.

7. Bid Security/Earnest Money

7.1 **Bid Security** amount should be enclosed along with the Technical Bid for an amount of **Rs.25, 000/- (Rs. Twenty-Five Thousand Only)** in the form of Bank Guarantee from any Indian Scheduled Bank valid for one year from the date of opening the tender or by way of Demand Draft drawn in favor of Director, IGIMS, Patna, failing which the tenders will be out rightly rejected. Bid Security/EMD, if already deposited against other tenders, shall not be adjusted against this tender.

7.2 The "**Bid Security/Earnest Money Demand Draft**", in case of unsuccessful Bidders, shall be retained by the Purchaser, upto a maximum period of One year from the date of opening of the Bids or till the finalization of the tender, whichever is later. The Bid security shall be refunded to the unsuccessful tenderers on written request. No interest will be payable by the Purchaser on the Bid Security/EMD.

7.3 The Bid Security/Earnest Money shall be forfeited;

- a) If a Bidder withdraws his bid during the period of bid validity specified by the Bidder in the Bid; or
- b) In the case of the finally selected Bidder, if the Bidder fails;
 - i. to sign the Contract in accordance with Clause 17; or
 - ii. if, at any stage, any of the information/declaration is found false

7.4 Bid security/Earnest Money in respect of the finally selected Bidder(s) will be discharged upon the Bidder(s) executing the Contract and successful completion of work-

8. Period of Validity of Bids

Bids shall remain valid for One year from the date of bid opening prescribed by the Purchaser. The Purchaser may reject a bid valid for a shorter period as non-response

9. THE FORWARDING LETTER/UNDERTAKING ALONGWITH CHECKLIST FOR TERMS & CONDITIONS DULY SIGNED SHOULD INVARIABLY BE RETURNED ALONGWITH QUOTATIONS FURNISHED, FAILING WHICH THE TENDER SHALL BE REJECTED.

10. Terms and Conditions of Tendering Firms

10.1 Printed terms and conditions of the Bidder will not be considered as forming part of their Bids. In case terms and conditions of the contract applicable to this invitation of tender are not acceptable to any Bidder, he should clearly specify deviation in his Bid.

11. Bid Requirements

11.1 The Bidder must quote for the equipment with all items and quantities as listed under the Schedule for Requirements.

- 11.2 Arithmetical errors will be rectified on the following basis: If there is a discrepancy between the unit price and the total unit price as declared in the Price Schedule the unit price shall prevail and the total price shall be corrected. If there is a discrepancy between words and figures, the amount in words will prevail. If the supplier does not accept the correction of the errors, its bid will be rejected.
- 11.3 The Bid Documents are not transferable and the cost of the documents is not refundable under any circumstances.
- 11.4 Bids from Bidders who have not downloaded the Bid document or Bids not accompanied by Bid Security or Bids from representatives without letter of Authority from the manufacturers will be summarily rejected.
- 11.5 Telex/Fax bids and incomplete bids will be summarily rejected.
- 11.6 Bidders should enclose, along with the Techno-Commercial Bid of their offers, the full details including proposed configuration of offers with full documentation, descriptive literature/leaflets supplementing the description and point out any special feature of their system. All documentation is required to be in English.
- 11.7 The bid shall contain no interlineations, erasures or overwriting except as necessary to correct errors made by the Bidder, in which case such corrections shall be initialed by the person or persons signing the bid.
- 11.8 All pages of the Bid being submitted must be signed and sequentially numbered by the Bidder.
- 11.9 All information in the offer must be in English. Information in any other language must be accompanied by its authenticated translation in English. Failure to comply with this may render the offer liable to be rejected. In the event of any discrepancy between the offer in a language other than English and its English translation, the English translation will prevail.

12. Bid Prices

- 12.1 IN CASE OF IMPORT, THE TENDERERS ARE REQUIRED TO QUOTE FOB & CIF VALUE SEPARATELY DULY MENTIONING THE BREAKUP DETAILS FOR FREIGHT & INSURANCE. THIS CONDITION SHOULD BE STRICTLY ADHERED TO FAILING WHICH THEIR TENDER WILL BE SUMMERLY REJECTED.
- 12.2 The bidder shall indicate on the Price Schedule attached to these documents the Unit Prices and the total Unit Prices of the goods it proposes to supply under the Contract in the following manner:
- i) Unit FOB & CIF price separately for each item (excluding customs duty) giving breakup of freight & Insurance charges.
 - ii) Customs duty on per unit CIF price
 - iii) Local levies, if any, on per unit price
 - iv) Other incidental charges, if any, on per unit price
 - v) Unit price, for destination
 - vi) Total unit price, for destination. Excise duties, sales tax if included should be explicitly specified.
- 12.3 It should be noted that payment by the Purchaser towards customs duty and local levies, if any would be made on actual. The purchaser would provide appropriate forms applicable to purchases made.
- 12.4 The prices quoted by the Bidder and accepted by the sub-committee duly constituted by IGIMS shall hold good till the completion of the works and no additional claims will be admissible on account of any price variation or fluctuation in market rates.
- 12.5 Payments made consequent to any notified change in custom duties, excise duties and sales tax (both increase and decrease) shall be to the Purchaser's account. For such claims of variation, the

Bidder shall produce the Government notification as documentary evidence. Price variation due to any other cause shall be on Bidder's account.

- 12.6 The finally selected Bidder will have to apply to the proper Government Authority for grant of requisite License /foreign exchange for such items as required and the purchaser will only tender such assistance, as considered necessary.
- 12.7 The firm has to provide the breakup expenditure of different quoted items as well as total expenditure clearly for the system.

13. Contents of Bid

The Bid prepared by the Bidder shall comprise of the following two components:

- a) **Technical Bid** comprising of the following and to be filled on the format sheets provided in the tender document. This is mandatory:-
- i) Bidders particulars (Annexure – A)
 - ii) Bid Form (Annexure – B)
 - iii) Bidder profile (Annexure – C)
 - iv) Manufacturers' Authorization Form (Annexure – D)
 - v) Proforma of Guarantee for supply of spares during the post warranty period (Annexure – E)
- b) **Financial Bid / Price bid** to be submitted in the company's letter head duly signed & sealed by their authorized signatory / ies.

14. Procedure for Submission of Bids

- 14.1 It is proposed to have a **Two Cover System** for this tender
- a) Technical Bid in one cover
 - b) Financial Bid in one cover
- 14.2 Technical Bid of the Tender should be covered in a separate sealed cover super-scribing the wordings "Technical Bid".

PLEASE NOTE THAT PRICES SHOULD NOT BE INDICATED IN THE TECHNICAL BID. TENDERS SUBMITTED WITHOUT FOLLOWING THE TWO BID SYSTEM PROCEDURE WILL BE SUMMARILY REJECTED.

- 14.3 Commercial Bid of the tender should be covered in a separate sealed cover superscribing the wordings "Commercial Bid".
- 14.4 Both the Technical Bid cover and Commercial Bid cover prepared as above are to be kept in a single sealed cover superscribed with Tender Number and Group..
- 14.5 The cover thus prepared should also indicate clearly the name and address of the Bidder.
- 14.6 Each copy of the tender should be a complete document and should be bound as a volume. Different copies must be bound separately.
- 14.7 The sealed cover as mentioned at Clause 14.4 above shall be deposited with the **Director, IGIMS, Sheikhpura, Patna through registered / speed post / courier services.**

15. Opening of Bids by Purchaser

- 15.1 The bids (technical only) will be opened in the presence of Bidders/representatives who choose to attend on the date and time as mentioned. The Bidders/ representatives who are present shall sign a register evidencing their attendance. The Bidder's representatives shall furnish letter of authority from their firm to attend the bid opening. Financial bids of Bidders, whose bids are found technically suitable (after the presentation, if any,) only will be opened later on. The information

pertaining to opening of Financial Bid will be sent to separately. The decision of the sub-committee on technical suitability shall be final and shall not be opened for discussion.

16. Award of Contract

Prior to the expiry of the period of bid validity, the Purchaser will notify the finally selected Bidder(s) in writing by registered letter or by e-mail, to be confirmed in writing by registered letter or by Hand in person, that its bid has been accepted. If a need for extension of the bid validity period arises, it should be extended by mutual agreement. The notification of award will constitute the formation of the Contract.

17. Signing of Contract

- 17.1 At the same time as the Purchaser notifies the finally selected Bidder(s) that its bid has been accepted, the finally selected Bidder(s) shall collect the Work Order from the office of the Director.
- 17.2 Within 7 (seven) days of the receipt of Work Order, the finally selected Bidder(s) shall start the work and complete it within fifteen (15) days.
- 17.3 Without prejudice to any legal remedy, failure of the finally selected Bidder(s) to comply with the requirement of Clause 7.3 (a) or Clause 7.3 (b) shall constitute sufficient grounds for the annulment of the award and forfeiture of the bid security, in which event the Purchaser may make the award to the next lowest evaluated Bidder or call for new bids.

18. Inspection and Tests

The Purchaser shall have the right to inspect and/or test the equipment for conformity to the Contract Specifications.

- 18.1 In case any inspected or tested equipments fail to conform to the specifications, the Purchaser may reject them and the supplier shall either replace the rejected equipments or make all alterations necessary to meet specification requirements free of cost to the Purchaser.
- 18.2 The supplier shall provide installation and standard tests for the individual equipment before the delivery of the system at site.
- 18.3 The supplier shall test each individual equipment and the complete system after installation at site and prepare a test report. This shall be compared with the factory test report to ensure that there is no deterioration in the equipment parameters during storage, transportation and installation.
- 18.4 Leaflets and literature should invariably be attached for ready references along with complete documentation of all the measurements conducted during installation period which shall be submitted by the supplier for future reference.
- 18.5 The technical problems faced during installation, testing and commissioning period and their solutions shall be submitted by the supplier at the time of handing over the completed works.
- 18.6 For the purpose of taking over the equipment/system supplied pursuant to this contract, an acceptance test shall be carried out at the Purchaser/Consignees destination site. The equipment which meets the acceptance test shall only be accepted by the Purchaser.
- 18.7
 - (a) Acceptance Test at site shall be conducted of individual equipment and complete system to ensure that individual equipment and complete system meets the technical specifications and other operational and technical requirements of tender.
 - (b) The Purchaser shall have the right to reject any individual equipment or complete system, if in its opinion the same does not meet technical specifications, operational or technical requirements. The decision of the purchaser in this regard shall be final.

- (c) The delivery, installation or commissioning shall not be deemed to have been completed unless all the equipments and systems are accepted by the purchaser.

19. Spare Parts

- 19.1 The Bidder will undertake that supplies of necessary maintenance equipment and spare parts will be made available for all items/equipments and the complete system for at least ten years on a continuing basis. However, this does not relieve the supplier of any warranty obligations under the Contract.
- 19.2 The Bidder shall include in his tender, the details of essential spares, their quantity and unit prices as per schedule of requirements. Detailed explanation to confirm that quantity of spares quoted as per requirement of this clause shall be given.
- 19.3 In addition to the essential spares, Bidder shall indicate additional recommended quantities of spares for efficient maintenance of the equipment and the systems for a period of 5 years, after the completion of warranty period, to ensure that the quality and reliability objective is achieved. The details on which unit price and the total cost or recommended spares is based shall be included in the tender as an option. However, the cost of such recommended spares shall not be considered for tender evaluation

20. Warranty

- 20.1 Complete system (including re-installed equipments at Manifold Room should have comprehensive (labour, spares and all type of consumables) onsite warranty for five years; commencing from the date of issue of installation certificate by the institute.
- 20.2 Incremental Cost (if any) for, upgradation, if required, should form part of the contract for the Warranty period.
- 20.3 The technical maintenance personnel of the supplier responsible for supervision and maintenance shall be available to reach the site(s) within 24 hour's notice.
- 20.4 If the performance of any individual equipment or system is not satisfactory, the same shall be replaced by the supplier free of cost.
- 20.5 If it is found that to meet the performance criteria, any extra equipment is required the same will be provided free of cost by the supplier.
- 20.6 All faults appearing and their rectification shall be periodically advised to the hospital, the period being not more than a month.
- 20.7 Any lacuna or lacunae noticed in the functioning of the installation as a result of any design feature shall be rectified by the supplier free of cost.
- 20.8 **The Supplier shall fully associate the engineers and technicians of the Institute during installation, testing, commissioning, operation and maintenance period.**

21. After Sales Services and Comprehensive Maintenance Contract (Post Warranty CMC)

After sales services will be provided by the supplier during and after guarantee period of the equipment. Details along with the yearly comprehensive maintenance charges for five year after warranty shall be forwarded provided.

22. Previous Installations

The names and address of the institutions/hospitals where the supplier has already installed/supplied the equipment indicating the dates of installations may be given (in India and abroad).

23. Delivery, Installation and Commissioning

- 23.1 Delivery of the goods at the Institute premises shall be completed by the Supplier within 15 days from the date of Supply Order.
- 23.2 The installation, testing and commissioning of the proposed system shall be completed within 21 days from the date of Supply Order, failing which necessary action as deemed fit under rules, will be taken against the defaulter.

24. Incidental Services

- 24.1 The supplier is required to provide Hardware and Software up gradation from time to time, at mutually agreed terms. During warranty all Software updated version / up gradations are expected to be provided at free of cost to Purchaser.
- 24.2 Further, any bugs/shortcomings detected by the purchaser/user as well as the supplier himself shall be rectified at free of cost to purchaser beyond warranty period

25. Site Preparation

- 25.1 The site for installation of the equipment shall be provided by the purchaser as per the required specification and environmental conditions before the installation of System.
- 25.2 Site Plan and System layout plan including civil/electrical work or other related works shall be prepared by the supplier.
- 25.3 Earthling arrangements for all the equipment shall be completed as per standard practice

26. Termination for default

The purchaser may without prejudice to any other remedy for breach of contract, by written notice of default sent to the supplier, terminate the contract in whole or in part.

- i) If the supplier fails to deliver or install system within the time period(s) specified in the contract.
OR
- ii) If the supplier fails to perform any other obligation(s) under the contract.

27. Use of Contract Document & Information

The supplier shall not, without the Purchaser's prior written consent, disclose the contract, or any provision thereof, or any specification, plan, drawing, pattern, sample of information furnished by or on behalf of the Purchaser in connection therewith, to any person other than a person employed by the supplier in the Performance of the contract

28. Property Rights

The Supplier shall indemnify the Purchaser against all third party claims of infringement of patent, copyright, trademark, license of industrial design rights, software piracy arising from use of the goods or any part thereof in the Purchaser's country.

29. Payment

Procedure for payment: The paying authority on production of the following documents shall make 90% Payment.

- i. Invoice in triplicate are to be submitted to the paying authority along with the other documents after completion of the supply.
- ii. Stock Entry Certificate is to be obtained in the body of the Invoice in triplicate.
- iii. The original Challan Copy.

- iv. Installation and Completion certificate of the Turnkey job issued by the institute authority.
- v. Warranty certificates.

The balance 10% payment will be released after expiry of warranty period of five years or on submission of Bank Guarantee of the same amount with a validity to cover up the warranty period.

30. Packing and Marketing

Best trade packing suitable for safe Rail/Road/Air/Sea transit shall be used subject to packing and marking being acceptable to the Inspecting Authority.

- (a) The supplier shall provide such packing of the goods as is required to prevent their damage or deterioration during transit to their final destination as indicated in the contract. The packing shall be sufficient to withstand without limitation, rough handling during transit and exposure to extreme temperature, salt and precipitation during transit and open storage. Packing case, size and weights shall take into consideration, where appropriate, the remoteness of the Goods final destination and absence of heavy handling facilities at all points in transit.
- (b) The packing marking shall show the description of quantity of contents, the name of the consignee and address, the gross weight and distinctive number of mark sufficient for purpose of identification. Each package shall contain:
 - i) A packing note quoting the name of the purchaser.
 - ii) The number and date of order
 - iii) Nomenclature of the goods
 - iv) Schedule of parts of each complete equipment giving part number with reference to assembly.

Notwithstanding anything stated in this clause, the supplier shall be entirely responsible for loss, damage, deterioration, depreciation of the goods due to faulty packing.

31. PREPARATION AND DELIVERY OF TENDER

Tender documents must be signed by the tenderers in full along with their stamp.

32. Jurisdiction

The courts at Patna (Bihar) will have the jurisdiction to try any matter, dispute or reference between the parties arising out of the contract. It is specifically agreed that no court outside and other than Court shall have jurisdiction in the matter.

33. Force Majeure

Any failure of omission or commission to carry out the provision of the contract by the supplier shall not give rise to any claim by any party, one against the other, if such failure of omission or commission arises from an act of God, which shall include all acts of natural calamities such as fire, flood, earthquake, hurricane or any pestilence or from civil strikes, compliance with any statute and/or regulation of the Government, lockouts and strikes, riots, embargo or from any political or other reasons beyond the supplier's control including war (Whether declared or not) civil war or state or insurrection, provided that notice or the occurrence of any event by either party to the other shall be given within two weeks from the date of occurrence of such an event which could be attributed to Force Majeure conditions.

The Institute reserves the right to accept or reject in whole or in part any or all the quotations received without assigning any reasons thereof.

34. Termination for Insolvency

The purchaser may at any time terminate the contract by giving written notice to the supplier, without compensation to the suppliers, if the supplier becomes bankrupt or otherwise insolvent (which events shall of themselves be a breach of the contract on the part of the supplier), provided such termination will not prejudice or affect any right of action or remedy which has accrued or will accrue thereafter to the purchaser.

35. Termination for Convenience

The purchaser, may by written notice sent to the supplier terminate the contract, in whole or in part, at any time for its convenience. The notice of termination shall specify that termination is for the Purchaser's convenience, the extent to which performance of work under the contract is terminated becomes effective.

The good that are complete and ready for shipment within 15 days after the supplier's receipts of notice of termination shall be purchased by the purchaser at the contract terms and prices. For remaining goods the purchaser may elect.

- a) To have any portion completed and delivered at the contract terms and prices; and/or
- b) To cancel the remainder

36. Government Language

The contract shall be written in the language of the Bid (English Language) as specified by the Purchaser. All correspondence and other documents pertaining to the contract shall be in English.

37. Up time guarantee:

The firm should provide uptime guarantee of 95% (95% of 365 days).

38. Downtime penalty Clause

41.1 During the comprehensive warranty period, the guarantee uptime of 95% of 365 days will be ensured. In case the down time exceeds the 5% limit penalty of extension of guaranty period by one weak for each additional day of down time will be enforced.

41.2 The principals or their agents are required to submit a certificate that they have satisfactory service arrangements and fully trained staff available to support the uptime

**Director,
I.G.I.M.S. – Patna.**

SPECIAL TERMS AND CONDITIONS FOR TENDER SUBMISSION

1. The tenderer should have been in this business for a period of **at least three years** in the country in relation to the type of equipment/drugs for which the quotations/tenders are being submitted.
2. A proof of ownership/partnership etc. shall be submitted along with verification of address, telephone & fax numbers.
3. The attested copies of latest Income tax clearance certificate and sales tax certificate, if applicable, should be submitted in absence of which tender shall be rejected.
4. The supplier should submit a statement of overall turnover for the previous three years. If applicable a copy of the applicants annual report and accounts for each of the last three years should also be submitted.
6. The tenderer is also required to submit performance report from other similar organizations where the firm is registered for supply and erection of similar projects of hospital equipments/System. He will also submit list of organizations where the System has been installed by the firm.
7. The tenderer has to give a affidavit on non-judicial stamp paper that the firm has not been blacklisted in the past by any Institution - Government/Private.
8. The tenderer is also requested to submit authority letter from manufacturers/principals of supplying equipment /drugs without which tender will not be considered.
9. The tenderer/supplier has to give an affidavit on a non-judicial stamp paper that there is no Vigilance / CBI case pending against the firm/supplier.
10. If the tenderer gives a false statement on any of the above information the firm/supplier will not be considered and their quotation/tender shall be rejected and the security deposited shall be forfeited.
11. The Institute will have the right to reject any tender without assigning any reason.
12. The manufacturer should submit all the quotations directly or through their authorized distributor provided the manufacturer accepts responsibility for any lapse on the part of distributor and authorization certificate must be enclosed.
13. Quality assurance certification like ISO 9000 series should be enclosed wherever applicable.
14. It is mandatory for bidder(s) to provide maintenance visits on per month basis during warranty as well as during Comprehensive Annual Maintenance Contract (including Labour + Spares + all type of consumables) period and also attend all breakdown calls within 24 hours from the receipt of the information.

**Director,
I.G.I.M.S. – Patna.**

To be enclosed with Technical Bid

ANNEXURE-A

BIDDER PARTICULARS

1. Name of the Bidder :
2. Address of the Bidder:
3. Name of the Manufacturer (s):
4. Address (es) of the Manufacturer:

Telephone :

Telex :

Fax :

e-mail address :

Date

Signature

Name
Designation
Company

Company Seal

To be enclosed with Technical Bid

ANNEXURE-B

BID FORM

Dated:

To,

Sir,

Having examined the Bidding Documents of Tender No. _____
undersigned offer to supply, install, commission, operate maintain _____ and
we undertake, if our bid is accepted, to complete delivery of all the items specified in the contract
Within _____ weeks calculated from the date of receipt of your Notification of Award
and to complete the installation, testing commissioning.....

Signature and Seal

(In the capacity of)

Only Authorized to sign bid for and on behalf of.....

To be enclosed with Technical Bid

ANNEXURE-C

BIDDER PROFILE

A. General Information:

(i) Location of Corporate Headquarters :

(ii) Date and Country of Incorporation :

(iii) Manufacturing Facility (S)

**Location
Size
Capacity**

(iv) No. of Service Facility(S) in India

**Location
Strength
Area Covered**

(v) Average yearly turnover for last three years:

(vi) Geographical Distribution of the Supplier:

**No. of Offices
Locations
Staff strength**

(vii) Total No. of installations of the system offered.

(viii) No. of Employees

	Total No.	Manufacturing	R&D (If any)
Hardware Maintenance			
Software			

B. Reference of Major installation with similar products (attach documents in support, if available)

S. No.

Customer Name, Address Product Description Telephone Fax Number (No. of Machines installation year wise)

Date.....

Signature and seal of bidder

To be enclosed with Technical Bid

ANNEXURE-D

PROFORMA FOR AUTHORITY FROM MANUFACTURERS

No.....

Dated.....

To,

Dear Sir,

Sub: Tender No.....

(Name and Address of the Authorized representative) to represent us, to tender, negotiate and conclude the contract on our behalf with; you against Tender no.....
No company/firm or individual other than M/s..... are authorized to represent us in regard to this business against this specific tender.

Yours faithfully,
Signature and seal
Name.....
For & on behalf of M/s
.....
(Name of Manufacturers)

Note: This letter of authority should be on the letter head of the manufacturing concern and should be signed by a person competent and having the power of attorney to bind the manufacturers.

To be enclosed with Technical Bid

ANNEXURE-E

**PROFORMA OF GUARANTEE FOR SUPPLY OF SPARES DURING
POST WARRANTY PERIOD**

To:

Dear Sir,

In consideration of the (hereinafter referred to as "Purchaser" which expression shall unless repugnant to the context or meaning thereof include its successors, administrators and assignees) having awarded to M/s..... with its Registered/Head office at (hereinafter referred to as the "Supplier" which expression shall unless repugnant to the context or meaning thereof, include its successors, administrators, executors and assignees), a contract by issue of the Purchaser's letter of Award no..... dated entering into a formal contract to that effect with the Purchaser on vide agreement dated..... (hereinafter referred to as the contract).

We the supplier hereby give a guarantee for the supply of all necessary spares demanded for the routine and emergency maintenance of being supplied by us to for a period of not less than 5 years after the warranty period of 5 years and life time spares thereafter in case asked for by the purchaser.

We further clarify that for the first 5 years i.e. warranty period of 5 years, we are covered by the warranty clause as mentioned. For the remaining period of 5 Years and thereafter for the life time, a detailed list of spares will be supplied to the purchaser for the purpose of enabling him to decide spares needed for routine and emergency maintenance.

Dated..... day of.....20.....

Witness :

(Signature)

(Name of manufacturers)
Signature and Seal

Name:
For & on behalf of M/s

SCHEDULE-1

SCHEDULE OF REQUIREMENT

Part – A: Re-installation, Renovation and Extension of Medical Gas Pipeline System at Kidney Transplant Unit of I.G.I.M.S. – Patna.

- i. To install Bed Head Panel with Suction, Oxygen and Compressed Air Outlets in newly constructed cubical cabins (Qty. – 06 Nos.)
- ii. To extend and re-install the pipeline system with existing Medical Gas Pipeline System already operational at Dialysis Room.

Details of Items to be required for the said work (tentative):

Sl. NO.	Description	Qty. (approx.)
1.	Medical Grade Copper Pipes: a. 12mm OD x 0.9mm Thick b. 15mm OD x 0.9mm Thick c. 22mm OD x 0.9mm Thick d. 28mm OD x 1.0mm Thick	55 Mtrs. 76 Mtrs. 76 Mtrs. 76 Mtrs.
2.	Valve with Valve Box and Pressure Gauge (3 – Gas Systems)	02 Nos.
3.	Medical Gas Line Pressure Area Alarm (Oxygen, Vacuum & Air – 3 Gas System)	01 No.
3.	Bed Head Panel with facility of Gas Outlets (Double Lock Outlet with Parking Facility) for Oxygen, Vacuum and Air with 5/15 Power Sockets.	06 Nos.
4.	Oxygen Flow Meter (0 – 15 LPM) brass body with unbreakable Humidifier Bottle	12 Nos.
5.	Ward Vacuum Unit 600ml Jars with Regulator	12Nos.
6.	High Pressure Tube (Oxygen & Vacuum)	20 Mtrs.
7.	Low Pressure Tube	10 Mtrs.

Part – B: To provide Medical Gas Pipeline System (Oxygen & Vacuum only) in Deluxe Room No: 48, 49 and 51 by extending the system from Deluxe Room No. – 52:

Details of Items to be required for the said work (tentative):

Sl. NO.	Description	Qty. (approx.)
1.	Medical Grade Copper Pipes: a. 12mm OD x 0.9mm Thick b. 15mm OD x 0.9mm Thick c. 22mm OD x 0.9mm Thick	20 Mtrs. 73 Mtrs. 73 Mtrs.
2.	Valve with Valve Box and Pressure Gauge (2 – Gas Systems)	01 No.
3.	Medical Gas Line Pressure Area Alarm (Oxygen, Suction – 2 Gas System)	01 No.
3.	Bed Head Panel with facility of Gas Outlets (Double Lock Outlet with Parking Facility) for Oxygen, Vacuum and Air with 5/15 Power Sockets.	03 Nos.
4.	Oxygen Flow Meter (0 – 15 LPM) brass body with unbreakable Humidifier Bottle	06 Nos.
5.	Ward Vacuum Unit 600ml Jars with Regulator	06 Nos.
6.	High Pressure Tube (Oxygen & Vacuum)	10 Mtrs.
7.	Low Pressure Tube	10 Mtrs.

Part – C: To connect Gas Manifold Room (Ward Block – G.F.) with Main Manifold Room (Diagnostic Block – G.F.; Near Microbiology Department):

Details of Items to be required for the said work (tentative):

Sl. NO.	Description	Qty. (approx.)
1.	Medical Grade Copper Pipes: a. 28mm OD x 1.0 mm Thick (for oxygen) b. 28mm OD x 1.0 mm Thick (for comp. air) c. 54mm OD x 1.0 mm Thick (for vacuum)	250 Mtrs. 250 Mtrs. 250 Mtrs.
2.	Valve with Valve Box and Pressure Gauge (3/4 – Gas Systems)	02 Nos.
3.	Medical Gas Line Pressure Area Alarm (Oxygen, Suction, Compressed Air – 4 Gas System)	01 No.

Part – D: To change Gas Outlets (Oxygen & Vacuum) installed at MICU, CCU and Isolation & provide Medical Gas Pipeline facility (Oxygen & Vacuum) in NICU:

Details of Items to be required for the said work (tentative):

Sl. NO.	Description	Qty. (approx.)
1.	Medical Grade Copper Pipes: a. 12mm OD x 0.9mm Thick b. 15mm OD x 0.9mm Thick c. 22mm OD x 0.9mm Thick	40 Mtrs. 70 Mtrs 70 Mtrs.
2.	Valve with Valve Box and Pressure Gauge (2 – Gas Systems)	02 Nos.
3.	Medical Gas Line Pressure Area Alarm (Oxygen & Vacuum – 2 Gas System)	01 No.
3.	Bed Head Panel with facility of Gas Outlets (Double Lock Outlet with Parking Facility) for Oxygen (two nos.) and Vacuum (1 No.) with 5/15 Power Sockets.	04 Nos.
4.	Oxygen Flow Meter (0 – 15 LPM) brass body with unbreakable Humidifier Bottle	08 Nos.
5.	Ward Vacuum Unit 600ml Jars with Regulator	04Nos.
6.	High Pressure Tube (Oxygen & Vacuum)	10 Mtrs.
7.	Low Pressure Tube	10 Mtrs.

Note:

1. The quantity mentioned is only the tentative requirement and may increase or decrease as per the decision of Tender Inviting Authority. The rates quoted should not vary with the quantum of the order or the destination.
2. The payment will be made after satisfactory completion of work and based on actual measurement of the items used.
3. The power supply at proposed manifold room will be provided by the institute. However, the electrical supplies to Audio / Visual alarms are to be provided by the successful bidder.
4. The sketch map of the area to be covered under medical gas [pipe line system through this tender may be obtained from office of the Senior Bio-Medical Engineer, I.G.I.M.S. – Patna.

5. The financial bid should be quoted in following format:-

Part – A: Re-installation, Renovation and Extension of Medical Gas Pipeline System at Kidney Transplant Unit of I.G.I.M.S. – Patna.

Sl. NO.	Description	Unit Price	Qty. (approx.)	Amount
1.	Medical Grade Copper Pipes: a. 12mm OD x 0.9mm Thick b. 15mm OD x 0.9mm Thick c. 22mm OD x 0.9mm Thick d. 28mm OD x 1.0mm Thick		55 Mtrs. 76 Mtrs. 76 Mtrs. 76 Mtrs.	
2.	Valve with Valve Box and Pressure Gauge (3 – Gas Systems)		02 Nos.	
3.	Medical Gas Line Pressure Area Alarm (Oxygen, Vacuum & Air – 3 Gas System)		01 No.	
3.	Bed Head Panel with facility of Gas Outlets (Double Lock Outlet with Parking Facility) for Oxygen, Vacuum and Air with 5/15 Power Sockets.		06 Nos.	
4.	Oxygen Flow Meter (0 – 15 LPM) brass body with unbreakable Humidifier Bottle		12 Nos.	
5.	Ward Vacuum Unit 600ml Jars with Regulator		12Nos.	
6.	High Pressure Tube (Oxygen & Vacuum)		20 Mtrs.	
7.	Low Pressure Tube		10 Mtrs.	
Taxes (If Any)				
Net Amount:				

Part – B: To provide Medical Gas Pipeline System (Oxygen & Vacuum only) in Deluxe Room No: 48, 49 and 51 by extending the system from Deluxe Room No. – 52:

Sl. NO.	Description	Unit Price	Qty. (approx.)	Amount
1.	Medical Grade Copper Pipes: a. 12mm OD x 0.9mm Thick b. 15mm OD x 0.9mm Thick c. 22mm OD x 0.9mm Thick		20 Mtrs. 73 Mtrs. 73 Mtrs.	
2.	Valve with Valve Box and Pressure Gauge (2 – Gas Systems)		01 No.	
3.	Medical Gas Line Pressure Area Alarm (Oxygen, Suction – 2 Gas System)		01 No.	
3.	Bed Head Panel with facility of Gas Outlets (Double Lock Outlet with Parking Facility) for Oxygen, Vacuum and Air with 5/15 Power Sockets.		03 Nos.	
4.	Oxygen Flow Meter (0 – 15 LPM) brass body with unbreakable Humidifier Bottle		06 Nos.	
5.	Ward Vacuum Unit 600ml Jars with Regulator		06 Nos.	
6.	High Pressure Tube (Oxygen & Vacuum)		10 Mtrs.	

7.	Low Pressure Tube		10 Mtrs.	
			Add Taxes (If Any)	
			Net Amount:	

Part – C: To connect Gas Manifold Room (Ward Block – G.F.) with Main Manifold Room (Diagnostic Block – G.F.; Near Microbiology Department):

Details of Items to be required for the said work (tentative):

Sl. NO.	Description	Unit Price	Qty. (approx.)	Amount
1.	Medical Grade Copper Pipes: a. 28mm OD x 1.0 mm Thick (for oxygen) b. 28mm OD x 1.0 mm Thick (for comp. air) c. 54mm OD x 1.0 mm Thick (for vacuum)		250 Mtrs. 250 Mtrs. 250 Mtrs.	
2.	Valve with Valve Box and Pressure Gauge (3/4 – Gas Systems)		02 Nos.	
3.	Medical Gas Line Pressure Area Alarm (Oxygen, Suction, Compressed Air – 4 Gas System)		01 No.	
			Add Taxes (If Any)	
			Net Amount:	

Part – D: To change Gas Outlets (Oxygen & Vacuum) installed at MICU, CCU and Isolation & provide Medical Gas Pipeline facility (Oxygen & Vacuum) in NICU:

Details of Items to be required for the said work (tentative):

Sl. NO.	Description	Unit Price	Qty. (approx.)	Amount
1.	Medical Grade Copper Pipes: a. 12mm OD x 0.9mm Thick b. 15mm OD x 0.9mm Thick c. 22mm OD x 0.9mm Thick		40 Mtrs. 70 Mtrs 70 Mtrs.	
2.	Valve with Valve Box and Pressure Gauge (2 – Gas Systems)		02 Nos.	
3.	Medical Gas Line Pressure Area Alarm (Oxygen & Vacuum – 2 Gas System)		01 No.	
3.	Bed Head Panel with facility of Gas Outlets (Double Lock Outlet with Parking Facility) for Oxygen (two nos.) and Vacuum (1 No.) with 5/15 Power Sockets.		04 Nos.	
4.	Oxygen Flow Meter (0 – 15 LPM) brass body with unbreakable Humidifier Bottle		08 Nos.	
5.	Ward Vacuum Unit 600ml Jars with Regulator		04Nos.	
6.	High Pressure Tube (Oxygen & Vacuum)		10 Mtrs.	
7.	Low Pressure Tube		10 Mtrs.	
			Add Taxes (If Any)	
			Net Amount:	

SCHEDULE-3

DETAIL TECHNICAL SPECIFICATIONS OF VARIOUS ITEMS

1. Distribution Piping:

SCOPE

The scope of work shall cover all distribution piping and terminal units for oxygen, nitrous oxide, vacuum and compressed air.

MATERIALS

Solid drawn, seamless, de-oxidized, non-arsenical, half-hard, tempered and de-greased copper pipe conforming to EN 13348: 2008. All copper pipes will be de-greased & delivered capped at both ends. The pipes will be accompanied with manufacturers test certificate for the physical properties & chemical composition. Copper pipe will also have third party inspection certificate from Lloyd's' Register Services. The Pipe Sizes to be used are from among as under: Copper fittings shall be made of copper and suitable for a steam working Pressure of 17 bar and especially made for brazed socket type connections.

All copper fittings will be conforming to EN 1254-1, should be factory de-greased, certified, and individually packed and identified for medical use. Fittings should be kite marked up to 54 mm size.

2. Isolation valves

The isolation valves will be Non Lubricated, 900 turn level, Ball type, suitable for oxygen service. All valves shall be pneumatically tested for twice the working pressure and factory degreased for medical gas service before supply.

3. Service valve box

2 /3/4 Gas types.

INSTALLATION & TESTING

Installation of piping shall be carried out with utmost cleanliness. Only pipes, fittings and valves which have been de-greased and fittings brought in polythene sealed bags shall be used at site. Pipe fixing clamps shall be of nonferrous or non-deteriorating plastic suitable for the diameter of the pipe.

All joints shall be made of copper to copper and brazed by silver brazing filler material without use of any flux. All brazing shall be done by using a brazing rod CP 104 (5% silver copper phosphorous brazing alloy) and copper-to-brass or gunmetal shall only be joints using brazing rod AG 203 (43% Silver-copper-zinc-brazing alloy) manufactured to EN-1044. Inert gas welding technique should be used by oxygen free Nitrogen gas inside copper pipes while brazing to avoid carbon deposition.

COPPER PIPE'S mm	THICKNESS	OUTER DIAMETER	12 mm	0.9
15 mm	0.9 mm			
22 mm	0.9 mm			
28 mm	0.9 mm			
54 mm	1.0 mm			

Adequate supports shall be provided while laying pipelines to ensure that the pipes do not sag. Suitable sleeves shall be provided wherever pipes cross through walls / slabs. All pipe clamps shall be non-reactive to copper. After erection, the pipes will be flushed and then pressure tested with dry air at a pressure equal to 1.5 times of the working pressure or 150 psig, whichever is higher for a period of not less than 24 hours.

All the piping system shall be tested in the presence of the site-engineer or his authorized representative.

PAINTING

All exposed pipes should be painted with two coats of synthetic enamel paint and colour codification should be as per IS : 2379 of 1963.

4. Digital Alarm System :

Four Channel Microprocessor Controlled Alarm for Pneumatic & Vacuum Services should have the following features:

- Digital Display of Line Pressure for all the services with factory calibrated pressure sensors.
- Color coded LED Display of Line pressure status (High – Caution – Normal – Caution–Low)
- Audible Alarm for High & Low pressure condition.
- Test and Alarm Acknowledge (Mute) facility. (Alarm acknowledges (Mute) time span is programmable from 1 to 60 min).
- Programming facility of alarm limits from front panel (Password protected).
- Facility to connect to remote alarm box by potential free contacts provided in the alarm box.
- Small and compact design. Light Weight (3 kg)
- Imported highly sensitive gas pressure sensors & USA/CE marked power supply.
- Mounted on a powder coated MS box.
- Nut & Nipples are to be provided for connection with Pneumatic supply line.
- Low voltage internal operation with input power supply of 220V AC.
- Battery Backup
- Easy wall mounting facility

5. Double Lock Outlet

Outlets shall be manufactured with a 165 mm length, Copper inlet pipe stub which is silver brazed to the outlet body. Body shall be of one piece brass construction. For positive pressure gas services, the outlet shall be equipped with a primary and secondary check valve and the secondary check valve shall have break safe mechanism and also comply to EN 737 pressure test standards and rated at minimum 200 psi in the event the primary check valve is removed for maintenance.

The outlet assembly should have separate colour coding for each services and will accept only corresponding gas specific adaptors. All outlets shall be cleaned and de-greased for medical gas service, factory assembled and tested. The medical gas outlets should be of quick connecting and wall mounted modular type.

6. BPC Flow meter with Humidifier :

Back Pressure Compensated flow meter will be of accurate gas flow measurement with following features:

- a. Control within a range of 0 – 15 lpm (calibration within +/- 10%).
- b. It will meet strict precision and durability standard.
- c. The flow meter body shall be made of brass chrome plated materials.
- d. The flow tube and shroud components shall be made of clear, impact resistant polycarbonate.
- e. Flow Tube shall have large and expanded 0 – 5 lpm range for improved readability at low flows.
- f. Inlet filter of stainless steel wire mesh to prevent entry of foreign particles.
- g. The humidifier bottle shall be made of unbreakable polycarbonate material and autoclavable at 121 degree Centigrade temperature.

7. Ward Vacuum Units:

- a. Ward Vacuum Unit shall be of light weight and compact. The unit will consist of a regulator,
- b. A 600 ml. Reusable collection jar, made of unbreakable poly carbonate material and fully autoclavable at 134 degree centigrade
- c. A wall bracket for mounting the jar assembly on the wall.
- d. The vacuum regulator shall be infinitely adjustable and have vacuum gauge which indicates suction supplied by the regulator. Safety trap shall be provided inside the jar to

safeguard the regulator from overflowing.

8. **Bed Head Panels for ICU/HDU**

Bed Head Panels horizontal/ vertical It should have the following features-

- Minimum length 1.2 meter.
- Efficient, safe & Robust design in extruded 19luminium section.
- Smooth curved surfaces, with acceptable colour choice should have an integrated rail system to mount accessories Segregation of services i.e. low voltage supplies, high voltage supplies, and medical gases should be maintained throughout.
- Entire pipe line should run in continuous horizontal panels with no break for each unit & length as per area where it has to be installed.
- Facility as per under
- Oxygen -2, Vacuum-1, Medical air -1, Infusion pump mount pole with adopter for mounting at least two pumps.
- Electrical outlets- 3. Combined 15/5
